

NOTES
DIMENSIONS IN [] ARE INCH EQUIVALENTS.

REV	DATE	DESCRIPTION	BY
-	12-23-14	NEW DRAWING [CT102529]	BGW
A	3-24-15	(D-6) MOUNTING HOLE DIMS ADDED [CT108839]	BGW


ON COMPOSITE DWGS, SEE PART NO. FOR REVISION LEVEL
UNLESS OTHERWISE SPECIFIED:
1) DIMENSIONS ARE IN MILLIMETERS
2) TOLERANCES ARE:
X.XX ± 0.25
X.X ± 1.0
X ± 1.5
ANGLES ± 0° 30'

APPROVALS: APPROVED KJB 12-23-14, DATE 12-23-14
DRAWN: BGW 12-23-14
CHECKED: KJB 12-23-14
APPROVED: KJB 12-23-14

KOHLER CO. METRIC PRO-E
POWER SYSTEMS, KOHLER, WI 53044 U.S.A.
THIS DRAWING IN DESIGN AND DETAIL IS KOHLER CO. PROPERTY AND MUST NOT BE USED EXCEPT IN CONNECTION WITH KOHLER CO. WORK. ALL RIGHTS OF DESIGN OR INVENTION ARE RESERVED.

TITLE: DIMENSION PRINT, 20RESD
SCALE: 0.40 CAD NO. SHEET: 1 of 2
DWG NO. ADV-8758

20RESD



ACCEPTABLE

- 1) EXHAUST IS AIMED AWAY OR PARALLEL TO STRUCTURE.
- 2) EXHAUST IS NOT DIRECTED AT PLAY AREAS, PATIOS OR OTHER AREAS WHERE PEOPLE CONGREGATE.
- 3) THE NEAREST WINDOW, VENT, DOOR OR SIMILAR STRUCTURE OPENING IS AT LEAST 5 FEET FROM THE EXHAUST END OF THE SET.
- 4) SET HAS PROPER OFFSET FROM STRUCTURE.
- 5) WINDOWS & DOORS ON ADJACENT WALLS ARE CLOSED.
- 6) FURNACE AND OTHER SIMILAR INTAKES ARE AT LEAST 10 FEET FROM EXHAUST END OF SET.
- 7) WEED BARRIER AND 3 INCH THICK GRAVEL BASE OR CONCRETE PAD LOCATED TO PREVENT GRASS & WEEDS FROM GROWING TOO CLOSE TO THE SET.
- 8) NO PLANTS, SHRUBS OR OTHER COMBUSTIBLES ALLOWED IN CLEARANCE AREA. (MINIMUM 4FT FROM EXHAUST END)
- 9) REFER TO OWNERS MANUAL FOR OTHER INSTALLATION CONSTRAINTS.
- 10) NO PLANTS, SHRUBS, OR OTHER COMBUSTIBLES ALLOWED WITHIN 18" OF THE AIR INTAKE

NOTE:

1) THE REQUIRED DISTANCE FROM A STRUCTURE IS DEPENDENT ON STATE AND LOCAL CODES. NFPA37 STANDARDS FOR THE INSTALLATION AND USE OF STATIONARY COMBUSTION ENGINES AND GAS TURBINES.

20RESD

REV	DATE	ON COMPOSITE DWGS, SEE PART NO. FOR REVISION LEVEL	BY	UNLESS OTHERWISE SPECIFIED - 1) DIMENSIONS ARE IN MILLIMETERS 2) TOLERANCES ARE:
-	12-23-14	NEW DRAWING [CT102529]	BGW	X.XX ±
A	3-24-15	SEE SHEET 1 [CT108839]	BGW	X.X ±
				X ±
				ANGLES ±

APPROVALS	DATE	 THIRD ANGLE PROJECTION	SURFACE FINISH MAX.
DRAWN	12-23-14		
CHECKED	KJB 12-23-14		
APPROVED	KJB 12-23-14		

KOHLER CO. METRIC PRO-E	
POWER SYSTEMS, KOHLER, WI 53044 U.S.A.	
THIS DRAWING IN DESIGN AND DETAIL IS KOHLER CO. PROPERTY AND MUST NOT BE USED EXCEPT IN CONNECTION WITH KOHLER CO. WORK. ALL RIGHTS OF DESIGN OR INVENTION ARE RESERVED.	
TITLE DIMENSION PRINT, 20RESD	
SCALE 0.03	CAD NO.
DWG NO. ADV-8758	SHEET 2 of 2